TOWN OF BURGAW, NORTH CAROLINA

2017-2018 System Performance Annual Report

Wastewater Collection System

This report provides performance information on the Town of Burgaw sewer collection system for the fiscal year of 2017-2018. This report is required under the provisions of the Clean Water Act of 1999, House Bill 1160 ratified on July 20, 1999.

COLLECTION SYSTEM

I. General Information

Facility Name:	Burgaw Collection System
Responsible Entity:	Town of Burgaw
Person in Charge:	Robert A. Moore, Public Works Director
Applicable Permits:	WQCS00150

II. System Description

The collection system consists of approximately 24 miles of gravity sewer lines, 18 miles of force mains and 17 pump stations. All are stations are monitored by radio signal, 24 hours per day, seven days per week. The Town of Burgaw currently monitors 3 SIU's (Significant Industrial Users) in it's Pretreatment Program.

III. Performance

During this report period there were no reportable sewer spills from the collection system.

IV. Notification

This report is published on the Town of Burgaw web site at www.townofburgaw.com. In addition, copies are available for review at the City Hall offices at 109 North Walker Street and the Public Utilities Department at 213 S. McRae Street in Burgaw.

V. Certification

I certify under penalty of law that this report is complete and accurate to the best of my knowledge. I further certify that this report has been made available to the users or customers of the named system and that those users have been notified of its availability.

Robert A. Moore 8-29-18

Robert A. Moore
Public Works Director
Town of Burgaw